THIS IS A TWO-SIDED DOCUMENT



PO Box 99 · 1133 NYS Route 86 Ray Brook, NY 12977 Tel: (518) 891-4050 www.apa.ny.gov

APA General Permit/Order 2019G-1

Permit #: 2025-0009

Certification for the Replacement of Certain Utility Poles

This certification under General Permit 2019G-1 is granted to National Grid, authorizing the replacement of utility poles as described herein in the Town of Duane, Franklin County.

All terms and conditions of this certification shall apply to the applicant and any individual, contractor, municipality, or other entity undertaking the authorized work on the project site.

This certification does not grant any right to trespass upon the lands or interfere with the riparian rights of others, nor does it authorize the impairment of any easement, right, title, or interest in real or personal property.

Nothing contained in this certification shall be construed to satisfy any legal obligations of the applicant to comply with all applicable laws and regulations or to obtain any governmental approval or permit from any entity other than the Agency, whether federal, state, regional, or local.

PROJECT DESCRIPTION AS PROPOSED

The project as conditionally approved herein involves the replacement of four existing utility poles ranging from 34 feet to 39 feet above grade with four new utility poles with an overall height of 43 feet above grade.

The project is shown on a six-sheet set of plans titled, "National Grid 27-24-30946933," dated April 5, 2024, and received by the Agency on January 9, 2025.

Reduced-scale copies of these plans are attached to this certificate for easy reference. The original, full-scale maps and plans described in this paragraph are the official plans for the project, with copies available upon request from Adirondack Park Agency headquarters in Ray Brook, New York.

CONDITIONS

- 1. The height and location of the replacement utility poles and any associated vegetative cutting and maintenance shall comply with all applicable utility laws, regulations, safety requirements, and company specifications.
- 2. For projects involving wetlands:
 - a. Whenever practicable, access through wetlands shall occur on frozen ground and with the use of wide-tracked vehicles.

GP2019G-1

Project No.: 2025-0009

 All activities shall occur in compliance with the "Best Management Practice for Preventing the Transportation of Invasive Plant Species," published by Environmental Energy Alliance of New York, 4/26/2012.

- c. No temporary access structure, including bog mats and work pads, shall be located within a wetland for more than 30 days.
- d. Existing poles to be replaced shall be removed completely from the wetland, including the portion of the pole that was below grade.
- e. If any hole left after removal of a pole or created for a replacement pole is to be backfilled with gravel or other ballast, the top six inches shall be covered with organic soil and the final elevation shall be the same as the surrounding wetland surface.
- f. The total area of wetland disturbance shall be limited to that necessary for replacement of the utility poles.
- 3. When brought from off-site, all vehicles, construction equipment, and hand excavation tools to be used on the project site shall be clean and free of soil, mud, or other similar material. If washed on the project site, equipment shall be washed in one location to prevent the distribution of propagules among different wash sites. All vehicles, construction equipment, and hand excavation tools used in areas that may contain existing invasive species shall be thoroughly cleaned prior to moving to other areas.
- 4. The Agency may conduct on-site investigations, examinations, and evaluations as it deems necessary to ensure compliance with the terms and conditions of this certification.

Project No.: 2025-0009

CERTIFICATION issued this 5 day of February, 2025.

Stephanie L. Petith

Reg No 01PE6279890

Commission Expires April 15, 20 35


ADIRONDACK PARK AGENCY


Environmental Program Specialist 3 (EPS3)


STATE OF NEW YORK **COUNTY OF ESSEX**


On the 5th day of 4ebruary in the year 2025, before me, the undersigned, a Notary Public in and for said State, personally appeared Ariel Lynch, personally known to me or proved to me on the basis of satisfactory evidence to be the individual whose name is subscribed to the within instrument and acknowledged to me that they executed the same in their capacity, and that by their signature on the instrument, the individual, or the person upon behalf of which the individual acted, executed the instrument.


Notary Public. State of New York Qualified in Franklin County











Doc. # ST. 09.00.005

MU = @9-415B 0-15KV 3Φ - Bare MU = @9-415BCL 0-15KV 3Φ - Covered MU = @9-415BCL 0-15KV 3Φ - Covered

PRIMARY DEADEND DETAIL

SHAME OF THE PARTY	CUYING PER SECTION 3		ring.
EOGA ETE TW		" <u>\</u> 18	
2 HILLS CONTINUE DE LA CONTINUE DE L	/		
	/	(LEION)	
		177	P2025-0009
MJ COE			FINAL
(1)			MEW Y 'ORK Adirondack STATE OF
17 E13 E13		0	Date: January 9, 2025
v LE	[C4A]		BECEINED
			NEW PORK AGEN CY

525	+-		"[]]-TL 24	101
	240		"III-TL GA	901
		906	"I [[- T L 8 4	98
175	<u>G81</u>	592	"III-TL BA	G.18
477 AAC	336.4 AAC	JAAA QVI	BOLE SIZE	ATTACHMENT
MA[N LINE			3213 3 100	SEC BUKT
SPANS WITH 1/0 AAAC NEUIRAL				
ØZZ	220	220	"III-TL 24	6.18
132	135	135	"III-TL GA	6. 18
JAA 774	336.4 AAC	JAAA 0/1	BZIS BTO	TUBMHDATIA
	N FINE	[∀W	DOI C 613C	SEC BRKT
SPANS WITH 1/0 TRIPLEX SEC				
SEE 9-200 FOR ADDITIONAL INFORMATION ON MAXIMUM SPANS				

40" TO COMMUNICATIO/ ATTACHMENT

NOTES

Supersedes 7/20 Issue - Updated Drawing

This clearance can be reduced to a minimum of 56" if needed and if NESC midspan clearances are maintained (see Section 7.11 for required

THIS TABLE BASED ON EQUAL OWNERSHIP PERCENTAGE

midspan clearances).

2. For single phase delta circuit construction, omit the center phase.

7/24	91 7 -6	CONSTRUCTION STANDARD	national grid		
ISSUE	PAGE NUMBER	ОЛЕВНЕРО			
46° - 60° ANGLES / BACK-TO-BACK DEADENDS (TANGENT)					
14 (DELTA) AND 34 DEADEND CROSSARM POLE TOP - 0-15 KV					